



- H1 = POWER ON INDICATOR
- H5 = PUMP P1 DRY-RUN FAULT INDICATOR
- H6 = PUMP P2 DRY-RUN FAULT INDICATOR
- H7 = PUMP P3 DRY-RUN FAULT INDICATOR
- S4 = PUMP P1 DRY-RUN RESET PUSHBUTTON
- S5 = PUMP P2 DRY-RUN RESET PUSHBUTTON
- S6 = PUMP P3 DRY-RUN RESET PUSHBUTTON
- Q1 = MAIN DOOR INTERLOCKED ISOLATOR
- H2 = PUMP P1 OVERLOAD TRIPPED INDICATOR
- H8 = PUMP P1 RUNNING INDICATOR
- S8 = PUMP P1 STOP PUSHBUTTON
- S9 = PUMP P1 START PUSHBUTTON
- S1 = PUMP P1 OVERLOAD RESET PUSHBUTTON
- S7 = PUMP P1 DUTY/OFF SELECTOR
- H3 = PUMP P2 OVERLOAD TRIPPED INDICATOR
- H9 = PUMP P2 RUNNING INDICATOR
- S11 = PUMP P2 STOP PUSHBUTTON
- S12 = PUMP P2 START PUSHBUTTON
- S2 = PUMP P2 OVERLOAD RESET PUSHBUTTON
- S10 = PUMP P2 DUTY/OFF SELECTOR
- H4 = PUMP P3 OVERLOAD TRIPPED INDICATOR
- H10 = PUMP P3 RUNNING INDICATOR
- H11 = PUMP P3 INTERMITTENT RUN ACTIVATED INDICATOR
- S14 = PUMP P3 STOP PUSHBUTTON
- S15 = PUMP P3 START PUSHBUTTON
- S3 = PUMP P3 OVERLOAD RESET PUSHBUTTON
- S13 = PUMP P3 STANDBY DUTY/OFF/INTERMITTENT SELECTOR
- K4 = PUMP P3 INTERMITTENT RUN TIMER

RCS
RADWAY CONTROL SYSTEMS

RADWAY CONTROL SYSTEMS LTD.
 INDUSTRIAL AUTOMATION
 AND CONTROL SYSTEMS
 UNIT 1, WEST AVENUE, KIDSGROVE,
 STAFFORDSHIRE, ST7 7TR
 TEL : 0870 4606451 or 01782 776622
 FAX : 0870 4606452 or 01782 765409
 www.radway.co.uk email@radway.co.uk

Issue Code	Date	Name	DATE	PROJECT :	CUSTOMER :	TITLE :	Contract Number	SHEET
A	17/03/09	C.L.	17/03/2009					7
			DRAWN C. LORENZ				Drawing Number	OF
			APPROVED SEE SHEET 1					7